



ISO/IEC 17025
Accreditation No. 1031/47

Analysis / Test Report

Client : M. Water Co., Ltd.
204 Moo 3, T.Chamaep, A.Wangnoi, Phranakorn Sri Ayutthaya 13170
P/O :
Project Name :
Project Location :

Lot ID: 2564199

Date Received : Jan 06, 2026
Date Reported : Jan 16, 2026
Report Number : 3482740-1

Page 1 of 4

Sample Number	2564199-1					
Sampled Date	Jan 06, 2026 11:40 AM					
Sample Description	น้ำดื่มสปริงเคล เตือนมกราคม 2569					
Date Analysis Commenced	Jan 07, 2026					
Condition of Sample	Contained in two glass vials and eight plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)					

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Metals Testing							
Arsenic	mg/L	0.0003	0.0005	Not Detected	≤0.01	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
Barium	mg/L	0.0003	0.0005	Not Detected	≤0.7	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
Cadmium	mg/L	0.0003	0.0005	Not Detected	≤0.003	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
Chromium	mg/L	0.0003	0.0005	Not Detected	≤0.05	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
Copper	mg/L	0.0003	0.0005	Not Detected	≤1	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
Iron	mg/L	0.003	0.005	Not Detected	≤0.3	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
Lead	mg/L	0.0003	0.0005	Not Detected	≤0.01	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
Manganese	mg/L	0.0003	0.0005	Not Detected	≤0.05	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok

11/01/2026

19/01/2026

Approved by

Suwannee Chuamkeaw
Section Head

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. The report shall not be reproduced except in full without the written approval of the laboratory.



ISO/IEC 17025
Accreditation No. 1031/47

Analysis / Test Report

Client : M. Water Co., Ltd.
204 Moo 3, T.Chamaep, A.Wangnoi, Phranakorn Sri Ayutthaya 13170
P/O :
Project Name :
Project Location:

Lot ID: 2564199

Date Received : Jan 06, 2026
Date Reported : Jan 16, 2026
Report Number : 3482740-1

Page 2 of 4

Sample Number	2564199-1						
Sampled Date	Jan 06, 2026 11:40 AM						
Sample Description	น้ำดื่มสปิงเกิล เดือนกรกฎาคม 2569						
Date Analysis Commenced	Jan 07, 2026						
Condition of Sample	Contained in two glass vials and eight plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)						
Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Metals Testing							
Mercury	mg/L	0.0001	0.0005	Not Detected	≤0.001	In-house method : STM 05-007 based on United States Environmental Protection Agency, 2002, EPA Method 1631, Revision E	Bangkok
Selenium	mg/L	0.0003	0.0005	Not Detected	≤0.01	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
Zinc	mg/L	0.003	0.005	Not Detected	≤3	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
Microbiological Testing							
<i>Clostridium perfringens</i>	in 100 mL	-	-	Not Detected	Not Detected	In-house method STM No. 01-012 in connection with: - Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9274 B - FDA BAM online, 2001 (Chapter 16)	Bangkok
<i>Escherichia coli</i>	in 100 mL	-	-	Not Detected	Not Detected	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9221 F	Bangkok
<i>Salmonella spp.</i>	in 100 mL	-	-	Not Detected	Not Detected	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9274 A, B	Bangkok
Standard Plate Count	CFU/mL	-	-	<1	≤500	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9215 B	Bangkok

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. The report shall not be reproduced except in full without the written approval of the laboratory.

Approved by

Suwannee Chuamkeaw
Section Head

ADDRESS 104 Phatthanakan 40, Phatthanakan Rd., Khaeng Phatthanakan, Khet Suan Luang, Bangkok 10250 Thailand | PHONE +66 0 2760 3000 | FAX +66 0 2760 3197
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER



ISO/IEC 17025
Accreditation No. 1031/47

Analysis / Test Report

Client : M. Water Co., Ltd.
204 Moo 3, T.Chamaep, A.Wangnoi, Phranakorn Sri Ayutthaya 13170
P/O :
Project Name :
Project Location:

Lot ID: 2564199

Date Received : Jan 06, 2026
Date Reported : Jan 16, 2026
Report Number : 3482740-1

Page 3 of 4

Sample Number	2564199-1						
Sampled Date	Jan 06, 2026 11:40 AM						
Sample Description	น้ำดื่มสปริงเกลล์ เดือนมกราคม 2569						
Date Analysis Commenced	Jan 07, 2026						
Condition of Sample	Contained in two glass vials and eight plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)						
Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Microbiological Testing							
Staphylococcus aureus	in 100 mL	-	-	Not Detected	Not Detected	In-house method STM No. 01-054 in connection with: - Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9213 B - FDA BAM online, 2016 (Chapter 12)	Bangkok
Total Coliform	MPN/100mL	-	-	<1.1	<1.1	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9221 B	Bangkok
Water Testing							
Alkylbenzene Sulfonate as MBAS	mg/L	0.05	0.1	Not Detected	≤0.2	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 5540 C	Bangkok
Chloride as Cl	mg/L	0.06	0.2	0.2	≤250	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 4110 B	Bangkok
Color	Color unit	-	5	<5	≤5	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 2120 B	Bangkok
Cyanide as CN	mg/L	0.002	0.005	Not Detected	≤0.07	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 4500 - CN (C, E)	Bangkok
Fluoride as F	mg/L	0.05	0.1	Not Detected	≤0.7	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 4110 B	Bangkok
Nitrate as N	mg/L	0.06	0.2	Not Detected	≤4	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 4110 B	Bangkok

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. The report shall not be reproduced except in full without the written approval of the laboratory.

Approved by

Suwannee Chuamkeaw
Section Head



ISO/IEC 17025
Accreditation No. 1031/47

Analysis / Test Report

Client : M. Water Co., Ltd.
204 Moo 3, T.Chamaep, A.Wangnoi, Phranakorn Sri Ayutthaya 13170
P/O :
Project Name :
Project Location:

Lot ID: 2564199

Date Received : Jan 06, 2026
Date Reported : Jan 16, 2026
Report Number : 3482740-1

Page 4 of 4

Sample Number	2564199-1						
Sampled Date	Jan 06, 2026 11:40 AM						
Sample Description	น้ำดื่มสปริงเคล เดือนมกราคม 2569						
Date Analysis Commenced	Jan 07, 2026						
Condition of Sample	Contained in two glass vials and eight plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)						
Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Water Testing							
Odour		-	-	Odourless	Non Objectionable	In-house method : STM 04-025 based on Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 2150 B	Bangkok
pH at 25 degree C		-	-	7.9	6.5-8.5	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 4500 - H (B)	Bangkok
Phenol	mg/L	0.0005	0.001	Not Detected	≤0.001	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 5530 D	Bangkok
Sulfate	mg/L	0.15	0.5	<0.5	≤200	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 4110 B	Bangkok
Total Dissolved solids Dried at 180 degree C	mg/L	-	5	14	≤500	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 2540 C	Bangkok
Total Hardness as CaCO ₃	mg/L	0.5	1	<1	≤100	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 2340 C	Bangkok
Turbidity	NTU	-	0.1	0.15	≤5	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 2130 B	Bangkok

Guideline : Thai Industrial Standard No. 257-2549 refer to Notification of the Ministry of Industry No. 3470 (B.E. 2549).

Sampling By : Nattawut Sriprasert

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.
- Sampling is not included in scope of accreditation ISO/IEC 17025

11/01

19/01/2026

Approved by

Suwannee Chuamkeaw
Section Head

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. The report shall not be reproduced except in full without the written approval of the laboratory.

ADDRESS 104 Phatthanakan 40, Phatthanakan Rd., Khuwaeng Phatthanakan, Khet Suan Luang, Bangkok 10250 Thailand | PHONE +66 0 2760 3000 | FAX +66 0 2760 3197
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER



ISO/IEC 17025
Accreditation No. 1031/47

Analysis / Test Report

Client : M. Water Co., Ltd.
204 Moo 3, T.Chamaep, A.Wangnoi, Phranakorn Sri Ayutthaya 13170

P/O :

Project Name :
Project Location:

Lot ID: 2564199

Date Received : Jan 06, 2026

Date Reported : Jan 16, 2026

Report Number : 3482740-2

Page 1 of 1

Sample Number	2564199-1						
Sampled Date	Jan 06, 2026 11:40 AM						
Sample Description	น้ำดื่มสปริงเกลล์ เดือนมกราคม 2569						
Date Analysis Commenced	Jan 07, 2026						
Condition of Sample	Contained in two glass vials and eight plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)						
Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Metals Testing							
Aluminium	mg/L	0.003	0.005	Not Detected	≤0.2	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
Silver	mg/L	0.0003	0.0005	Not Detected	≤0.05	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 3125 B,3030 F	Bangkok
Water Testing							
Total Solids Dried at 103-105 degree C	mg/L	-	5	16	≤500	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 2540 B	Bangkok

Guideline : Notification of the Ministry of Public Health No. 61 B.E. 2524 & 135 B.E. 2534 on bottled drinking water (No.2) & 316 B.E. 2553

Sampling By : Nattawut Sriprasert

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.
- Sampling is not included in scope of accreditation ISO/IEC 17025

19/01/2026

Approved by

Chanattagarn Imchom
Section Head

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. The report shall not be reproduced except in full without the written approval of the laboratory.

ADDRESS 104 Phatthanakan 40, Phatthanakan Rd., Khwaeng Phatthanakan, Khet Suan Luang, Bangkok 10250 Thailand | PHONE +66 0 2760 3000 | FAX +66 0 2760 3197
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER



ISO/IEC 17025
Accreditation No. 1031/47

Analysis / Test Report

Client : M. Water Co., Ltd.
204 Moo 3, T.Chamaep, A.Wangnoi, Phranakorn Sri Ayutthaya 13170

P/O :

Project Name :
Project Location :

Lot ID: 2564199

Date Received : Jan 06, 2026

Date Reported : Jan 16, 2026

Report Number : 3482740-3

Page 1 of 1

Sample Number	2564199-1				
Sampled Date	Jan 06, 2026 11:40 AM				
Sample Description	น้ำดื่มสปริงเคล เดือนกรกฎาคม 2569				
Date Analysis Commenced	Jan 10, 2026				
Condition of Sample	Contained in two glass vials and eight plastic bottles, sample containers comply to pretreatment - preservation standards (APHA, USEPA)				
Analyte	Unit	LOD	LOQ (LOR)	Result	Method
Water Testing					
Bromate	mg/L	0.001	0.005	0.028	In-house method : STM 04-061 based on United States Environmental Protection Agency, 1999, EPA Method 300.1
					Bangkok

Sampling By : Nattawut Sriprasert

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.
- Sampling is not included in scope of accreditation ISO/IEC 17025

11/01

19/01/2026

Approved by

Siriluk P.

Siriluk Bunnak
Section Head

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. The report shall not be reproduced except in full without the written approval of the laboratory.

ADDRESS 104 Phatthanakan 40, Phatthanakan Rd., Khuwaeng Phatthanakan, Khet Suan Luang, Bangkok 10250 Thailand | PHONE +66 0 2760 3000 | FAX +66 0 2760 3197
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER